



10748 Deerwood Park Blvd South
Jacksonville, Florida 32256
Voice 904 256 2500
Fax 904 256 2501

April 30, 2021

TO: All Plan Holders

SUBJECT: Jacksonville Aviation Authority
Jacksonville International Airport
Jacksonville, Florida
Parking Garage Walkway Enclosure Replacement
(PedEx Enclosure Modifications)
JAA Contract No. C-855
JAA Project No. J2019-20
RS&H No. 201-0039-014
ADDENDUM NO. 4

Please find attached the Documents and Drawings for the above referenced Addendum No. 4.

This Addendum is hereby made a part of the Contract Documents, Specifications, and Drawings of the above referenced project. All other requirements of the original Contract Documents and Specifications shall remain effective in their respective order. **ACKNOWLEDGE RECEIPT OF THIS ADDENDUM (Pages 1 thru 3) BY INSERTING ITS NUMBER AND DATE IN THE BID SCHEDULE FORM.**

Please acknowledge receipt of this Addendum No.4 (Pages 1 thru 3) by signing and emailing this acknowledgement of receipt to Holly Harper at holly.harper@rsandh.com. Please use pdf format.

Sincerely,

Pete Novak
Project Manager

ACKNOWLEDGEMENT OF RECEIPT

Company _____

Name _____

Date Received _____



**JACKSONVILLE AVIATION AUTHORITY
JACKSONVILLE INTERNATIONAL AIRPORT
JACKSONVILLE, FLORIDA**

ADDENDUM NO. 04

For

**Parking Garage Walkway Enclosure Replacement
(PedEx Enclosure Modifications)**

JAA Contract No. C-855
JAA Project No. J2019-20
RS&H No. 201-0039-014

**JACKSONVILLE INTERNATIONAL AIRPORT
JACKSONVILLE, FLORIDA**



Jacksonville, Florida

April 30, 2021

ADDENDUM NO. 4

This Addendum is hereby made a part of the Contract Documents and Specifications of the above referenced project. All other requirements of the original Contract Documents and Specifications shall remain effective in their respective order. **ACKNOWLEDGE RECEIPT OF THIS ADDENDUM (Pages 1 thru 3) BY INSERTING ITS NUMBER AND DATE IN THE PROPOSAL FORM.**

A. CLARIFICATIONS

1. The bid date and time is extended until Tuesday, May 11, 2021 at 4:00 p.m. local time.
2. PROTECTION OF MOVING WALKWAYS: The moving walkways located inside the enclosure must be protected at all times during construction. All portions of the moving walkways (treads, balustrades, handrails, trim, etc.) shall be covered with plywood, sheet metal or other rigid material that will protect the walkways from damage from construction equipment, falling objects, etc. Plastic sheeting or other acceptable medium shall also be installed to prevent intrusion of dust, rain, etc. No work shall be performed from the moving walkway equipment, and no material storage will be permitted on the moving walkways.

Payment for this work shall be included in the Lump Sum cost for Item P-105-5.1, Temporary Construction Items.

End of Addendum No. 4